

Environmental Health Services Division

401 Fifth Avenue, Suite 1100
Seattle, WA 98104-1818

206-205-4394 Fax 206-296-0189

TTY Relay: 711

www.kingcounty.gov/health

Public Health
Seattle & King County



Electrical Bonding of Corrugated Stainless Steel Tubing in Fuel Gas Installations

- *2009 International Fuel Gas Code, Section 310.1.1*
- *2009 International Residential Code, Section G2411.1.1*
- *2009 NFPA-54 National Fuel Gas Code, Section 7.13.2*

The bonding connections shall be as shown in the detail below. The point of connection to the gas piping system shall be on the metal piping (not the CSST fitting) and shall be located between the gas meter and ahead of the first joint connection of the CSST system. For propane systems, the point of connection shall be on the metal piping between the entrance into the building and ahead of the first joint connection of the CSST system.

